PRI Construction Materials Technologies LLC



6412 Badger Drive Tampa, FL 33610 813.621.5777 https://www.pri-group.com/

Laboratory Test Report

Report for: Jason Rochester

Stepstone, LLC 17025 South Main St. Gardena, CA 90248

Product Name(s): Cal Arch Paver Caramel #1410 Light Sandblast (Slag)

Results Summary: Solar Reflectance: 0.364

Thermal Emittance: 0.91 SRI (Medium-Wind): 41

ASTM E 1980

Purpose: Determine the solar reflectance, thermal emittance, and solar reflectance index value(s)

of the tested product(s).

Test Methods: The test methods used included ASTM C 1549-16: Standard Test Method for

Determination of Solar Reflectance Near Ambient Temperature Using a Portable Reflectometer and ASTM C 1371-15: Standard Test Method for Determination of Emittance of Materials Near Room Temperature Using Portable Emissometers. Thermal emittance measurement for samples was modified in accordance with Devices and Services Company's Tech Note 04-1. Both of these methods are Energy Star, Leadership in Energy and Environmental Design (LEED), and Cool Roof Rating Council (CRRC)

approved methods for determining radiative properties.

The solar reflectance index (SRI) was calculated in compliance with ASTM E 1980-11: Standard Practice for Calculating Solar Reflectance Index of Horizontal and Low-Sloped

Opaque Surfaces.

2806T0003.4

The laboratory test results presented in this report are based on the material(s) supplied and tested. The results, and by extension any statements of conformity, opinions, or interpretations, apply the "simple acceptance" decision rule for measurement uncertainty accounting. This report is for the exclusive use of stated client. Only the client is authorized to permit copying or distribution of this report and then only in its entirety. PRI Construction Materials Technologies LLC assumes no responsibility nor makes a performance or warranty statement for this material or products and processes containing this material in connection with this report.

Stepstone, LLC
ASTM C 1549 for Reflectance, ASTM C 1371 for Emittance, and ASTM E 1980 for Solar Reflectance Index (SRI)
Caramel #1410 Light Sandblast (Slag)
Page 2 of 2

Sampling: The following materials were received by PRI.

ProductSourceDateSamplingCal Arch Paver Caramel #1410Gardena, CAMay 16, 2025Stepstone, LLCLight Sandblast (Slag)

Results:

ASTM E 1980

7.07 = 2000							
	Solar Reflectance ASTM C 1549 ¹		Thermal Emittance ASTM C 1371 ²		SRI		
					ASTM E 1980 ³		
	Avg.	Std.Dev.	Avg.	Std.Dev.	Low-Wind	Med-Wind	High-Wind
One (1) Specimen							
As Received	0.364	0.009	0.91	0.00	41	41	41
Test @ 73.4±1.8°F & 50±5%RH							

Note(s):

- 1- Reflectance measurements were conducted using a Devices and Services SSR-ER Version 6.4 Reflectometer operated in v5 emulation mode and calibrated with Devices and Services Reference Tile # D-18.
- 2- Emittance measurements were conducted using a Devices and Services Emissometer Model AE calibrated with Devices and Services Reference Standards: High Emittance: 0.86 and Low Emittance: 0.06. Thermal emittance measurement for sample was modified in accordance with Devices and Services Company's Tech Note 04-1.
- 3- SRI calculations per ASTM E 1980 Approach II utilize the following assumptions: Low-Wind $h_c = 5 \text{ W/m}^2 \cdot \text{K}$, Medium-Wind $h_c = 12 \text{ W/m}^2 \cdot \text{K}$, and High-Wind $h_c = 30 \text{ W/m}^2 \cdot \text{K}$.

Statement of Attestation: The Solar Reflectance Index of these samples was calculated in accordance with ASTM

E1980: Standard Practice for Calculating Solar Reflectance Index of Horizontal and Low-Sloped Opaque Surfaces. The laboratory test results presented in this report are representative of the materials supplied.

Signed: Juthony Catlett

Anthony Catlett

Date: May 29,2025

Manager

Report Issue History:

 Issue #
 Date
 Pages
 Revision Description (if applicable)

 Original
 05/29/2025
 2
 NA

END OF REPORT

2806T0003.4

The laboratory test results presented in this report are based on the material(s) supplied and tested. The results, and by extension any statements of conformity, opinions, or interpretations, apply the "simple acceptance" decision rule for measurement uncertainty accounting. This report is for the exclusive use of stated client. Only the client is authorized to permit copying or distribution of this report and then only in its entirety. PRI Construction Materials Technologies LLC assumes no responsibility nor makes a performance or warranty statement for this material or products and processes containing this material in connection with this report.